

SECTION 10 14 00 - SIGNAGE

1.1 ROOM NUMBERING

- A. Regional Materials: Dimensional letter signs shall be manufactured within 500 miles of Project site.
- B. All room signs shall conform to current ADA requirements.
- C. All spaces, including Rest Rooms, SER, Mechanical Rooms, Electrical Rooms, and Corridors, as well as assignable spaces, shall have unique room numbers assigned and be so labeled.
- D. All rooms at grade or above shall be numbered with three unique digits. No number may be used more than once. The floor accessed from grade is typically labeled with 100 series numbers. The floor above that, 200 series, etc.
- E. Floors immediately below the 100 series floor shall be numbered with two digits: 01 to 99. In special cases where buildings are located on hillsides, and separate floors are both accessible from a "grade," Architects shall confer with their designated contact at the University for specific instructions.
- F. Suffixes shall only be used within a specific discrete office complex, e.g., when the main entrance to an office is labeled 100, then within that office area rooms shall be labeled 100A, 100B, etc. Labeling on these inner rooms should start with the left most inner room when entering the suite and continue in a clockwise direction around the space.
- G. Prefixes, such as N101 and S101, are not acceptable.
- H. Sign materials and colors shall be approved by the Architect's designated contact at the University.
- I. All drawings, including construction drawings, shall reflect this numbering system.
- J. All drawings shall also include, by room number, the square footage of the individual spaces.
- K. All schedules in construction documents (materials, equipment, finishes, etc.) shall utilize this numbering convention.
- L. Generally, even numbers are used on one side of the corridor and odd numbers on the other.
- M. Adhesives: VOC content of 70 g/L or less.
- N. Adhesives: Comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- O. Stairwell signage shall be manufactured and installed in accordance with the current Ohio Fire Code, Section 1022.8.
- P. All stairwell signs shall be reviewed and approved by the CWRU EHS – Fire Safety prior to

manufacturing and installation.

END OF SECTION

SECTION 10 28 00 - TOILET, BATH, AND LAUNDRY ACCESSORIES

1.1 SUMMARY

- A. The following Toilet, Bath and Laundry Accessories shall be furnished by the Owner and installed by the Contractor

1.2 PRODUCTS

- A. **Paper Towel Dispenser:** Kimberly Clark, Series I, In-Sight, Smoke, G-HF108-90-25705, AKA 0099602.
 - 1. Surface Mounted.
- B. **Toilet Tissue Dispenser:** Kimberly Clark, Insight, Coreless Twin Jumbo Dispenser, Smoke, 0960810.
 - 1. Surface Mounted.
- C. **Soap Dispenser:** Deb, Cleanse Washroom 1000, Stock Code WRM1LDS.
 - 1. 1 Liter Capacity.
 - 2. Surface Mounted.
- D. **Hand Sanitizer Dispenser:** Deb, Instant FOAM 1000, 1FS1LDS.
 - 1. Surface Mounted.
- E. **Seat Cover Dispenser:** Hospitality Specialty Company, Half Fold Type, HG 1-2.
 - 1. Surface Mounted.

END OF SECTION

SECTION 10 44 00 - FIRE EXTINGUISHERS AND CABINETS

1.1 SUMMARY

- A. Provide all hand-carried fire extinguishers with fire extinguisher cabinets as required per NFPA and the local Fire Marshall.

1.2 WARRANTY

- A. Materials and Workmanship: Six (6) years from date of Substantial Completion.

1.3 PRODUCTS

- A. Fire Extinguisher types and sizes: Comply with NFPA and local Fire Marshall's requirements.
- B. Fire-Protection Cabinets:
 - 1. Type: Fire extinguisher.
 - 2. Cabinet Construction: Nonrated and rated as required for installation.
 - 3. Mounting: Recessed or semirecessed wherever possible.
 - 4. Style: If work is a renovation, fire extinguisher cabinets shall match existing cabinets in the area in style, glazing, and finish.
- C. Location and quantities: Comply with NFPA and local Fire Marshall's requirements.

END OF SECTION