SECTION 10 14 00 - SIGNAGE
Request updated guidelines from the Design Manager

SECTION 10 28 00 – TOILET, BATH, AND LAUNDRY ACCESSORIES
Request updated guidelines from the Design Manager

SECTION 10 44 00 - FIRE EXTINGUISHERS AND CABINETS

1.1 SUMMARY

A. Provide all hand-carried fire extinguishers with fire extinguisher cabinets as required per NFPA and the local Fire Marshall.

1.2 WARRANTY

A. Materials and Workmanship: Six (6) years from date of Substantial Completion.

1.3 PRODUCTS

A. Fire Extinguisher types and sizes: Comply with NFPA and local Fire Marshall's requirements.

B. Fire-Protection Cabinets:

1. Type: Fire extinguisher.
2. Cabinet Construction: Nonrated and rated as required for installation.
3. Mounting: Recessed or semirecessed wherever possible.
4. Style: If work is a renovation, fire extinguisher cabinets shall match existing cabinets in the area in style, glazing, and finish.

C. Location and quantities: Comply with NFPA and local Fire Marshall's requirements.

END OF SECTION