SECTION 33 05 00 - COMMON WORK FOR SITE UTILITIES

1.1 SITE DOMESTIC WATER DISTRIBUTION

A. Underground water piping shall be type "K" copper only. Piping over 3" shall be Ductile Iron class 55, cement lined and shall meet the ANSI standard in the plumbing code.

1.2 SITE STEAM AND CHILLED WATER DISTRIBUTION

A. Utility chilled water and steam is supplied by The Medical Center Co. All installations, tie-ins, etc. shall be in accordance with The Medical Center Co. specifications which are located at https://www.mcco.org/resources.php.

END OF SECTION